

Clarification #: 01**BCPS Southwestern Demolition****Date:** 02-06-26**Bids Due:** 02-11-26 @ 2:00 Local Time**From:** ELITE COMPANIES**Email:** bids@elite-companies.com**Clarification Details**

All Bid Packages: **Bid Proposals Sealed bids due 02/11/26 @ 2:00 pm local time**, will be received at Battle Creek Public Schools, located at 3 W Van Buren St W, Battle Creek, MI 49017 Attn: Director of Facilities. No faxed bids will be accepted. Envelopes are to be clearly marked as SEALED BID with Project name and number and Bid Package name and number. Bid Opening Bids will be publicly opened immediately after and read aloud at the Miller Stone Building, located at 77 Capital Ave NE, Battle Creek, MI 49017. Bids received after specified date and time will not be accepted and will be returned unopened. Bids will be accepted as determined to be in the Owner's best interest.

Bid Package 2.5: Not Reissued, Clarification; This package is to exclude hazardous waste material removal. It is unknown at this time if there is hazardous waste material on the site. ELITE will carry an allowance for removal of this work.

Bid Package 2.5: Not Reissued, Clarification; During window removal on the first floor on all sides of the school, the contractor is responsible for securing "boarding" window openings.

Bid Package 2.5: Not Reissued, Clarification;

Non Friable Materials - Window caulk, parapet caulk and roof flashing

The contractor can leave all category 1 and category 2 non friables in place during demolition if the material remains non friable throughout demolition.

All category 2 transite and flooring must be removed prior to demolition.

Attachments:

- Pre-Bid Sign-In Sheet
- Calhoun County Wage Rates
- Additional Site Photos

End of Clarification